MACALISTER & NUTTING

Tests of an Otto Suction Gas Producer and Gas Engine

Mechanical Engineering

B. S.

1906

UNIV. OF
ILLINOIS
LIBRARY

UNIVERSITY OF ILLINOIS
LIBRARY

Class 1906 Book M12 Volume



Digitized by the Internet Archive
in 2013

http://archive.org/details/testsofottosucti00maca

TESTS OF AN OTTO SUCTION GAS PRODUCER AND GAS ENGINE

BY

Robert Norman Macalister
Harry George Dallas Nutting

THESIS FOR THE DEGREE OF BACHELOR OF SCIENCE
IN MECHANICAL ENGINEERING

IN THE
COLLEGE OF ENGINEERING
OF THE
UNIVERSITY OF ILLINOIS
PRESENTED JUNE, 1906

1906
M12

UNIVERSITY OF ILLINOIS

June 1, 1906

THIS IS TO CERTIFY THAT THE THESIS PREPARED UNDER MY SUPERVISION BY

ROBERT NORMAN MACALISTER and HARRY GEORGE DALLAS NUTTING

ENTITLED TESTS OF AN OTTO SUCTION GAS PRODUCER

AND GAS ENGINE

IS APPROVED BY ME AS FULFILLING THIS PART OF THE REQUIREMENTS FOR THE DEGREE

OF Bachelor of Science in Mechanical Engineering

L. P. Breckenridge.

HEAD OF DEPARTMENT OF Mechanical Engineering

226389

1906
M12

TEST OF A 23 H.P. OTTO GAS ENGINE AND SUCTION PRODUCER.

Outline.

In writing this report the following outline has been followed:

(1) Preliminary Remarks.

(2) Purpose of Test.

(3) Description of Plant.

(4) Manner of Conducting Test.

(5) Calculations.

(6) Test Data or "Log" Sheets.

(7) Summary of Data and Results.

(8) Conclusions.

(9) Index.

Preliminary Remarks.

This report contains data and results of a test made in the Mechanical Engineering Laboratory of the University of Illinois, by R. N. Macalister and H. G. D. Nutting. The test covered a period of six days beginning at 8 A.M. Monday, April

The Rare Book & Manuscript Library
UIUC

16. and continuing to 3P.M. Saturday, April 21. Twenty four observers, mostly members of the Junior class in Mechanical Engineering recorded thedata, four men being used daily in addition to the two above mentioned. Each day one man was assigned to supervision only, to tend engine and producer and to keep watch on men and apparatus in general.

Purpose of Test.

The purpose of the test was to determine the following mechanical and thermodynamic efficiencies of the plant under ordinary commercial conditions, no attempt being made to obtain better conditions than would exist in the average power plant:

(1) Mechanical and thermodynamic efficiencies of engine.

(2) Efficiency of producer.

(3) Efficiency of plant as a whole.

(4) Utility of exhaust gas for the heating of buildings.

Description of Plant.

The plant consists of an Otto Gas Engine and Suction Producer of the following description and dimensions:

GAS ENGINE DATA.

No. Date

1. Name of engine- Otto
2. Manufactured by- Otto Gas Engine Co., Philadelphia, Penn.
3. Type- Four cycle.
4. Fuel used- Producer Gas (Suction).
5. Assumed heat in fuel- 130 B.T.U. per cu. ft.
6. H.P., builder's rating- 23
7. Floor space occupied- 55 sq. ft.
8. Weight-
9. Number of cylinders- One.
10. Diameter of fly wheels- 6 ft. 6in.
    Weight of the 2 wheels- 8160 lbs.
11. Diameter of belt pulley- 3 ft. 11 in.
    Width- 10 in.
12. Diameter of piston- 10 in. (9.997 in.)
    Length-
    Number of rings- 3
13. Stroke in inches- 19
    Displacement in cubic feet- .863
14. Clearance, cubic feet- .184 = 21.3 %
15. Length of connecting rod, inches- 47
16. R.P.M.- 226

17. Kind of Governor- Fly ball.

18. Method of Governing- Hit and miss.

19. Kind of ignition- Electric, make and break.

a Current required-

b Voltage-

c Kind of plug-

d Location- Center of head

e Battery recommended- Edison-Leland

f Number of cells- 6

g Specifications of coil-

(Magneto used- Auto-sparker)

(Voltage- Current-)

20. Kind of valves- Poppet- Positive opening and spring closing.

21. Dimensions of valves

	Diam.-ins.	Lift- ins.
a Gas valve-	2 1/4	
b Mixture valve-	3 5/8	
c Exhaust valve-	3 3/4	

22. Means of keeping constant proportions-

Cam shaft and air regulating valve.

23. Method of fuel feed- Suction.

29. Number of water inlets- One

Diameter- 3/4 ins.

30. Number of water outlets- One and drain.

Diameter- 3/4 in. and 1/2 in.

31. Best rate of water feed-

32. Kind of muffler- Tank. No water.

33. Means of clearing engine of exhaust gases- None.

34. Device for starting- Compressed air.

PRODUCER DATA.

1. Kind- Otto.

2. Type- Suction.

3. Fuel- Anthracite coal.

4. Builder's rating- 50 H.P.

5. Floor space-

6. Weight-

7. Height of center line above floor-

8. Extreme outside diameter-

9. Grate area- 1.58 sq. ft.

10. Builder's rated H.P. per sq. ft.- 31.6

11. Water heating surface- 10.86 sq. ft.

12. " " " per builder's H.P.- .217 sq. ft.

13. Weight of anthracite coal producer holds- 1018 lbs.

14. Thickness of fire brick lining- 8 in.

SCRUBBER.

1. Type- Coke and water spray- Water sealed.
2. Height-
3. Diameter-
4. Cubic contents-
5. Water inlet drain-
6. Best amount of water-

The operation of theplant is as follows: Referring to Plate I, a fire is built on the grate D, and the producer filled with anthracite pea coal to the charging door C. A blast is blown into the air tight ash pit E, by means of the hand blower G, and the fire is blown up until good gas is available at a gas cock in the outlet pipe, H. The valve, J, is then closed and thewater seal valve, K, opened, thus allowing the gas to pass through the scrubber, L, which is filled with coke over which water trickles. The water going down meets the up going gas and in this way cleans it. The gas then passes out at the top through the pipe, M, into a small storage tank, N, which is large enough to hold two or three charges of gas. From N the gas goes to the engine, P, through the valve R. After the engine is started, the fan, G, is stopped and the producer gets its draft from the suction of the engine, air going in at S, mixing with the steam from the water jacket, F,

and passing through the pipe, T, into the ash pit and up through the grate. When the engine is shut down for a time the gas is turned through the stack, U, on the engine side of the scrubber, or through the stack, V, on the producer side, depending upon the length of time it is not running.

Plate 8 is a general view of the plant and apparatus looking east. A is the producer, C the scrubber, B the engine, D the heater, which is not ordinarily a part of the plant, K a prony brake acting on the scale L, H the air pressure tank, G the air meter, Q the air regulating valve, M the chemistry apparatus, T the vaporizer water supply can, O the gas meter, P a tachometer, E theair compressor pumping into receiver N.

The engine is of the four cycle type andrated at 23 H.P. It is equipped with two extra heavy fly wheels to carry a lighting load with good regulation. Plate No. 2 shows a general design of engine. A is the gas inlet; B the gas valve box; C the mixture valve; and D the exhaust valve. E is the sparker actuating rod, F the governor, H the valve cams for mixture and exhaust valves, K is the cam for operating the gas valve.

Manner of Conducting Test.

The plant was first carefully examined for physical defects, both engine and producer being taken apart where this

was necessary. Measurements were made of the different parts, the cylinder clearance being determined by the water method. A preliminary run of a week was made previous to the test in order to get the plant into good running condition. During this time the apparatus was adjusted and calibrated, no attempt being made to record test data.

The test was started Monday at 8 A.M. under the following conditions: the coal magazine was filled to the top, the ash pit cleaned out, the vaporizer pan and ash pit floor filled with water, and readings were taken of all meters, thermometers, and other apparatus. At 3P.M. the following Saturday the test was closed under exactly the same conditions. The daily runs were about nine hours long and were started and stopped under the above conditions except that the ash was sometimes removed a short time before the stopping time. Indicator cards were taken every twenty minutes. Revolutions, explosions and brake pull were read every twenty minutes. Thermometers were read every half hour, and meters every hour. The heat value of the gas was taken with a Junker's Calorimeter every half hour, the other gas analysis being kept in operation continuously. Water was weighed in tanks on Buffalo scales except in case of scrubber water which was measured by a meter. It was intended to measure the air and gas used by means of meters but these proved defective in operation and it

became necessary to calculate volumes of air and gas from chemical analyses and the amount of carbon gasified. Coal and ash were weighed on Buffalo scales as delivered, a sample being taken from each lot for analysis. The work of the engine was absorbed by a Prony brake on an extension of the engine shaft. The gas analysis apparatus consisted of a Junker Calorimeter and an Orsat apparatus in connection with a Hempel explosion pipette. During the first three days the directions of the Otto Gas Engine Co. were followed as to the operation of the producer, i.e., the fire was filled, poked and cleaned every two or three hours. On the three following days the producer was kept full of coal as before, but was poked from above only two or three times during the day and the ash pit and fire doors were opened but once a day for the removal of ashes and cleaning of the fire, thus allowing the formation of an ash bed above the grate. All meters, scales, instruments and other apparatus used in this test, except thermometers, were calibrated, and their limits of error determined.

Methods of Calculating Results.

The methods of calculating results shown on Result Sheets were taken from the following:

"Working Details of a Gas Engine Test" by R. H. Fernald. A. S. M. E. Paper No. 950.

A. S. M. E. Paper No. 081. Vol. XXVII.

"Producer Gas and Gas Producers" by Samuel S. Wyer.

"Gas Engine Design" by Charles E. Lucke.

In addition to these some reference was had to

"Gas Engine and Producer Gas Plants" by R. E. Mathot,

"Suction Gas" by Oswald H. Haenssgen,

Catalogs of Morgan Gas Producer Co., and the

R. D. Wood and Co.,

" Hempel's Gas Analysis."

Conclusions.

From the results of this test as shown in the tables, the following conclusions may be drawn:

(1) The average mechanical and thermodynamic efficiency of the engine is fairly good.

(2) The thermodynamic efficiency of the producer is low.

(3) From (2) it follows that the efficiency of the plant is low.

(4) As seen from the result sheet about 11000 lbs. of water was heated per day up to 153°, or about 1375 lbs. per hour. Allowing a drop in the radiators of 30°, this would render available 30 x 1375 = 41250 B.T.U. per hour for heating, which would heat a room of about 10000 cu. ft. with 84 sq. ft. of glass surface, from 0° to 70°.

(5) The coal consumption per B.H.P. hour is higher than that usually guaranteed by builders of gas producers.

(6) The best results were obtained by themethod of firing adopted during the last three days of the test, and not by the method recommended by the builders.

(7) The best results would be obtained by having a bed of ashes on the grate, say about six inches, thus obtaining the same effect as given by thethick ash bed of a soft coal producer.

(8) The cooling water should leave the jacket at about 160° to 170° F. for best efficiency. Water at higher temperature than this has a tendency to carbonize the cylinder oil and to form scale in the cylinder jacket.

Observation of conditions during the test lead to the following conclusions:

(1) That there should be no connection between the exhaust pipe from engine and the chimney pipes from producer. The present construction allowed back firing of gas in producer and caused gas to be blown out into producer room, vitiating the atmosphere.

(2) That meters both water and gas even when carefully calibrated are not to be depended upon for accurate results.

(3) That the mixture valve of this engine is set too near the crank end, and if it should stick would be hit by the pis-

ton on the compression stroke. It would be better to have positively actuated valves rather than the present spring closing type.

(4) The low power developed by the engine was partly caused by high back pressure due to the heater and to the increased number of bends in the exhaust pipe.

(5) Failure to start an engine of this type may generally be traced to one of three causes:

a- poor compression.

b- poor gas.

c- defective sparker.

(6) In a test of this kind a good gas analysis is of utmost importance.



L DIAGRAM of
RATUS.



GRAPHICAL DIAGRAM of APPARATUS.



Diagram of Plant.

PLATE 1.

LIBRARY
OF THE
UNIVERSITY OF ILLINOIS



General View of Engine.

PLATE 2.

LIBRARY
OF THE
UNIVERSITY OF ILLINOIS



View of Air Pressure-tanks and Meter.

PLATE 3.

LIBRARY
OF THE
UNIVERSITY OF ILLINOIS.



General View of Plant looking West.

PLATE 4.

LIBRARY
UNIVERSITY OF ILLINOIS



Gas Analysis Apparatus.

PLATE 5.

UNIVERSITY OF ILLINOIS

Junker's Calorimeter

PLATE 6.

LIBRARY
OF THE
UNIVERSITY OF ILLINOIS.



Heater, and Gas Meter.

PLATE 7.

UNIVERSITY OF ILLINOIS



General View of Plant looking East.

PLATE 8.

LIBRARY
OF THE
UNIVERSITY OF ILLINOIS.



Prony Brake and Revolution Counter.

PLATE 9.

LIBRARY
OF THE
UNIVERSITY OF ILLINOIS



Front View of Engine showing Heater, Explosion Counter, and Tachometer.

PLATE 10.

UNIVERSITY OF ILLINOIS

SU

No.	Item.			Totals	Average
1	Date, Apr., 1904.				
2	Length of Test		7.	51.5	
3	Time intervals		0.		
4		Total	10.		
5	Rev.	R.P.M	2.		215.
6	and	Total	0.		
7	Explos.	E.P.M	6.		107.
8		Ratio	2.		
8.5		Temp	4.		153.7
9		Wgt.	7.	44179.	7350.
10	Jacket	Wgt.	2.		858.
11		Temp	4.5		94.3
12	Water	Max.			
13		Heat	0.		81000.
13.5		Heat	0.	4,154600.	
14		Wgt.	5.	16425.	2740.
15	Heater	Wgt.	9.		316.
16		Temp	0.5		91.1
17	Water	Heat	0.		28800.
17.5		Heat	0.	1,493,000.	
18		Total	00.		
19		Per h	0.		2277.
20	Air	Temp	0.		
21		Wgt.	.076		.076
22		Max.			
23		Spec	.2375		.2375
			.1691		.1691
24	Barometer, ins		29.22		
25		Total	0.		
26	Fuel	Per H	0.		1716.
27		Temp	5.		75.2
28	Gas	Wgt.	.0667		.0694
29		Max.	.567		.4875
30		Spec	.0203		.0204
31		Anal			
32		CO	5.2		6.7

SUMMARY and RESULTS.

No.	Item.								
1	Date, Apr., 1906	16.	17.	18.	19.	20.	21.	Totals	Average
2	Length of Test, hrs.	8.6	9.	8.6	9.0	9.3	7.	51.5	
3	Time intervals, min.	20.	20.	20.	20.	20.	20.		
4	Rev. and Explos. — Total rev. for day,	111456.	115020.	110940.	117180.	120528.	89040.		
5	Rev. and Explos. — R.P.M. (mean)	216.	213.	215.	217.	216.	212.		215.
6	Rev. and Explos. — Total explos. for day,	54713.	57240.	55212.	58860.	60264.	44520.		
7	Rev. and Explos. — E.P.M. (mean)	108.	106.	107.	109.	108.	106.		107.
8	Rev. and Explos. — Ratio, R.P.M. to E.P.M.	2.	2.	2.	2.	2.	2.		
8.5	Jacket Water — Temp. leaving, F°	153.	161.	151.	156.	147.	154.		153.7
9	Jacket Water — Wgt. for day, lbs.	* 7200.	7223.	7336.	7256.	8907.	6257.	44179.	7350.
10	Jacket Water — Wgt. per hr, lbs.	* 835.	803.	852.	806.	960.	892.		858.
11	Jacket Water — Temp. range, F°	94.	101.5	91.	96.5	88.3	94.5		94.3
12	Jacket Water — Max. vel., ft. per sec.								
13	Jacket Water — Heat absorbed per hr. B.t.u.	78500.	81700.	77600.	77800.	84850.	84300.		81000.
13.5	Jacket Water — Heat absorbed per day, B.t.u.	674500.	735000.	668500.	698500.	788000.	590100.	4,154600.	
14	Heater Water — Wgt. for day, lbs.	* 2500.	3185.	2790.	2482.	3653.	1815.	16425.	2740.
15	Heater Water — Wgt. per hr., lbs.	* 290.	354.	325.	276.	392.	259.		316.
16	Heater Water — Temp. range, F°	94.	89.9	91.	* 90.5	* 90.5	* 90.5		91.1
17	Heater Water — Heat absorbed per hr, B.t.u.	* 27250.	31750.	29600.	* 24950.	* 35450.	* 23400.		28800.
17.5	Heater Water — Heat absorbed per day, B.t.u.	* 234500.	286000.	255000.	* 224500.	* 329000.	* 164000.	1,493,000.	
18	Air — Total for day, cu. ft. st'd.	23730.	22500.	14650.	22150.	21500.	13500.		
19	Air — Per hr., cu. ft., st'd.	2760.	2500.	1700.	2460.	2315.	1930.		2277.
20	Air — Temp., F°	66.	72.7	75.	70.	70.	70.		
21	Air — Wgt. per cu. ft., st'd	.076	.076	.076	.076	.076	.076		.076
22	Air — Max. vel., ft. per sec.								
23	Air — Specific Heat, C_p	.2375	.2375	.2375	.2375	.2375	.2375		.2375
	Air — " " C_v	.1691	.1691	.1691	.1691	.1691	.1691		.1691
24	Barometer, ins. of mercury.	29.71	29.7	29.56	29.46	29.39	29.22		
25	Fuel Gas — Total for day, cu. ft., st'd.	19000.	18900.	12620.	17400.	13100.	8280.		
26	Fuel Gas — Per hr., cu. ft., st'd.	2200.	2100.	1470.	1935.	1410.	1180.		1716.
27	Fuel Gas — Temp., F°	70.	77.2	79.	* 75.	* 75.	* 75.		75.2
28	Fuel Gas — Wgt. per cu. ft. st'd	.0718	.0712	.0718	.0670	.0680	.0667		.0694
29	Fuel Gas — Max. vel., ft. per sec.	.386	.415	.404	.607	.546	.567		.4875
30	Fuel Gas — Specific heats, C_p and C_v	.0201	.0202	.0204	.0200	.0206	.0203		.0204
31	Fuel Gas — Analysis by vol. %								
32	Fuel Gas — CO_2	6.3	6.5	7.9	5.6	8.5	5.2		6.7

* Estimated.

	Date, Apr., 1906		21	Total	Average
33	Std.	CO	17.8		19.0
34	Fuel	O	.4		.8
35	Gas	CH_4	10.6		8.0
36	(continued)	H	8.4		6.8
37		N	57.6		58.7
38		B.t.u	128.9		120.3
39		Temp.,			
40		Wgt. p			
41	Std	Max.			
42	Mixture.	Spec.			
43	(Air,				
44	Gas,	Anal			
45	and	CO			
46	Neutrals)	CO			
47		O			
48		CH			
49		H			
50		N			
51		B.t.u			
52		Per hr.	970.		3839.
53		Wgt. p	.0850		.0852
54	Std	Spec	.239		.239
55	Exhaust	Anal			
56		CO	15.4		15.7
57	Gases	O	1.1		1.2
58		N	83.5		.83
59		Temp.			
60		Temp.*	140.		138.8
61	Valve in-	Gas	Open		
62	dex read-	Air	3.		
	ing.				
63	Value of n in				
64	Pressures	Atm			
65	from	Max.			
66	Indicator	Atmo			
67	Cards.	Expan			
68	lbs. per sq. in.	M.E.			
		#			

			16.	17.	18.	19.	20.	21	Total	Average
	Date, Apr., 1906									
33	Std.	CO	20.5	17.9	16.7	22.	18.9	17.8		19.0
34	Fuel	O	.85	.5	.65	.8	1.5	.4		.8
35	Gas	CH_4	6.5	7.0	7.2	5.4	11.0	10.6		8.0
36	(continued)	H	3.8	4.7	4.3	10.9	8.4	8.4		6.8
37		N	62.05	63.4	63.25	55.3	51.5	57.6		58.7
38		B.t.u. per cu.ft. by calorimeter(high)	116.2	116.2	110.0	120.8	129.8	128.9		120.3
39		Temp., F°								
40		Wgt. per cu. ft.								
41	Std	Max. vel., ft. per sec.								
42	Mixture.	Specific heats, Cp								
43	(Air,	Cv								
44	Gas,	Analysis by vol. %								
45	and	CO_2								
46	Neutrals)	CO								
47		O								
48		CH_4								
49		H								
50		N								
51		B.t.u. per cu. ft.								
52		Per hr., cu. ft.#	4690.	4425.	3090.	4180.	3680.	2970.		3839.
53		Wgt. per cu. ft.	.0849	.0848	.0852	.0855	.0859	.0850		.0852
54	Std	Specific heat, Cp	.239	.239	.239	.239	.239	.239		.239
55	Exhaust	Analysis by vol. %								
56		CO_2	15.05	15.4	15.2	16.0	17.3	15.4		15.7
57	Gases	O	2.05	.9	1.8	.9	.7	1.1		1.2
58		N	82.9	83.7	83.0	83.1	82.0	83.5		.83
59		Temp. al exhaust valve, F°								
60		Temp. after leaving heater, F°	133.	140.5	139.0	* 140.	* 140.	* 140.		138.8
61	Valve in-	Gas	Open	Open	Open	Open	Open	Open		
62	dex read-	Air.	3	3.	3.	3.	3,	3.		
	ing.									
63	Value of n in PV^n = Const.									
64	Pressures	At end of compression								
65	from	Max.								
66	Indicator	At end of expansion,								
67	Cards.	Expan. carried to end of stroke								
68	lbs. per sq. in.	M.E.P.								

Products of Comb. + Excess Air.

	Date, Apr.,		21	Totals	Average
68.5		Air	1.63		1.34
69		Mix			
70		Str			
71	Ratios	Tota			
72		Ma			
73		Max			
74	Value of R in F				
75	Temp. at compr				
76	Max. Temp., F°				
77		Av.	16.2		16.7
78		B.H	113.0	858.3	143.1
79		B.t.	50.		42383.
80		I.H.	23.7		22.9
81		B.t.	300.		58333.
82	Energies	Gas	60.		80.6
83		B.t	000.		205000.
84		Hea			
85		Hea			
86		Hea			
87		I.H.	7.5		6.25
88	Throttling, cu. ft.				
89	Throttling, %				
90	Work gained by				
91		Mec	.684		.73
92		The	.271		.206
93		The	.203		.172
94	Efficien-	The	.396		.285
95	cies.	The			
96		The	.75		.659
97		The			
98		The			
99	St'd Gas	Gas			
100	per hr.	Gas	73.0		103.7

#Calculated fro

			16.	17.	18.	19.	20	21	Totals	Average
Date, Apr.,										
68		Air to gas #	1.16	1.19	1.16	1.27	1.64	1.63		1.34
69		Mixture to neutrals								
70		Stroke to expans'n								
71	Ratios	Total vol. to clearance vol.		5.7						
72		Max. press. to M.E.P.								
73		Max. press. to compression.								
74	Value of R in PV = RT									
75	Temp. at compression, F°									
76	Max. Temp., F°									
77		Av. B.H.P.	15.4	16.7	16.2	17.6	17.8	16.2		16.7
78		B.H.P. hrs.	132.3	150.	139.	158.0	166.0	113.0	858.3	143.1
79		B.t.u. per hr. equiv. to B.H.P.	39200.	42500.	41250.	44800.	45300.	41250.		42383.
80		I.H.P.	22.0	23.5	21.	23.7	23.6	23.7		22.9
81		B.t.u. per hr. equiv. to I.H.P.	56000.	59800.	53500.	60300.	60100.	60300.		58333.
82	Energies	Gas H.P.	101.	96.	63.5	91.	72.	60.		80.6
83		B.t.u. per hr. equiv. to G.H.P.	256000.	244100.	161700.	231900.	183000.	152000.		205000.
84		Heat supplied per hr. from card, B.t.u.								
85		Heat extracted per hr. from card, B.t.u.								
86		Heat extracted per hr. by observ'n, B.t.u.								
87		I.H.P. – B.H.P.	6.6	6.8	4.8	6.1	5.8	7.5		6.25
88	Throttling, cu. ft.									
89	Throttling, %									
90	Work gained by complete expansion, ft. lbs.									
91		Mech. Eff. of Engine	.70	.712	.772	.743	.755	.684		.73
92		Thermal for B.H.P. (of Engine)	.153	.174	.255	.193	.248	.271		.206
93		Thermal for B.H.P. (of Plant)	.099	.109	.144	.137	.163	.203		.172
94	Efficien-	Thermal for I.H.P. (of Engine)	.219	.245	.331	.26	.328	.396		.285
95	cies.	Thermal for I.H.P. (of Plant)								
96		Thermal Eff. (of Prod. and Scrubr; Cold)	.647	.628	.564	.710	.66	.75		.659
97		Thermal Eff. (b)								
98		Thermal Eff. (c)								
99	St'd Gas	Gas per I.H.P., cu. ft.								
100	per hr.	Gas per B.H.P., cu. ft.	143.0	126.0	91.0	110.0	79.0	73.0		103.7

Calculated from Gas Analysis. Excess not included.

		PROD				
	Date, Apr.,		21.		Totals	Average
101	Temp. Gas leaving PP		525.			
102		Total ste	119.5			
103	Outside	Steam p	17.1			
104	items	Equiv. ir				
105	charged	Equiv. in				
106	against	Equiv. in				
107	Producer	Av. H.P. to				
108	Plant.	Total scr	11750.		86300.	
109		Water pe				
110		Water pe				
111		Proxima				
112		Mois	2.16			
113		Ash,	9.54			
114	Fuel	Volat	5.04			
115	consumed	Fixed	83.26			
116	in	Sulp	.37			
117	Producer	Mois	.07			
118	(including	Total coa	132.		1439.	
119	standby)	Total dry	129.		1400.	
120		Refuse	18.2		122.9	
121		Total ref	23.5		299.	
122		Total con	116.5		1269.	
123		Coal per	18.9			27.7
124		Dry Coa	18.4			27
125		Combusi	16.7			24.5
126		Equiv. c				
127		Equiv. d				
128		Equiv. c				
129		Per lb. co	3721.			
130		Per lb. di				
131	B.t.u. in	Per lb. co				
132	fuel.	From coa	5100o.			
133	(includes	From dry				
134	standby)	From co				
135	Fuel per	Coal as	11.95			
136	sq. ft. fuel	Dry coa				
137	bed per hr.	Combus				

PRODUCER

			16.	17.	18.	19.	20.	21.	Totals	Average
	Date, Apr.,									
101	Temp. Gas leaving Producer, F°		472.	488.	476.	*525.	*525.	*525.		
102	Outside items charged against Producer Plant.	Total steam used by producer, lbs.	155.	179.	185.2	158.	173.	119.5		
103		Steam per hr, lbs.	18.	19.9	21.6	17.6	18.6	17.1		
104		Equiv. in lbs. coal per hr.,								
105		Equiv. in dry coal per hr., lbs.								
106		Equiv. in combust. per hr. lbs.								
107		Av. H.P. to drive auxiliaries.								
108		Total scrubber water, lbs *	14400.	15100.	14400.	15100.	15600.	11750.	86300.	
109		Water per B.H.P. hr. of plant, lbs.								
110		Water per 1000 cu. ft. gas., lbs.								
111	Fuel consumed in Producer (including standby)	Proximate Analysis								
112		Moisture, %	2.16	2.16	2.16	2.16	2.16	2.16		
113		Ash, %	9.54	9.54	9.54	9.54	9.54	9.54		
114		Volatile, %	5.04	5.04	5.04	5.04	5.04	5.04		
115		Fixed Carbon, %	83.26	83.26	83.26	83.26	83.26	83.26		
116		Sulphur, %	.37	.37	.37	.37	.37	.37		
117		Moisture, Air drying, %	.07	.07	.07	.07	.07	.07		
118		Total coal consumed, lbs.	256.	291.5	278.5	239.0	242.0	132.	1439.	
119		Total dry coal consumed, lbs.	250.	284.0	272.0	234.0	236.0	129.	1400.	
120		Refuse from dry coal, %	14.7	27.5	36.3	13.0	13.2	18.2	122.9	
121		Total refuse from coal, lbs. (Dry)	36.8	78.2	99.	30.3	31.2	23.5	299.	
122		Total combustible, lbs.	226.0	257.3	246.	211.0	214.	116.5	1269.	
123		Coal per hr. as fired, lbs.	29.8	32.4	32.4	26.6	26.0	18.9		27.7
124		Dry Coal per hr., lbs.	29.1	31.6	31.6	26.0	25.4	18.4		27
125		Combustible per hr., lbs.	26.3	28.6	28.6	23.5	23.0	16.7		24.5
126		Equiv. coal per hr., lbs.								
127		Equiv. dry coal per hr., lbs.								
128		Equiv. combustible per hr., lbs.								
129	B.t.u. in fuel. (includes standby)	Per lb. coal as fired, B.t.u.	13721.0	13721.0	13721.	13721.	13721.	13721.		
130		Per lb. dry coal, B.t.u.								
131		Per lb. combustible, B.t.u.								
132		From coal as fired per hr., B.t.u.	396000.	420000.	482000.	353500.	345500.	251000.		
133		From dry coal per hr., B.t.u.								
134		From combustible per hr., B.t.u.								
135	Fuel per sq. ft. fuel bed per hr.	Coal as fired, lbs.	18.8	20.5	20.5	16.8	16.5	11.95		
136		Dry coal, lbs.								
137		Combustible, lbs.								

* Approximate

			21.	Totals	Average
138	Date, Apr.				
139		Per lb. c	77.1		72.8
140	St'd gas	Per lb. a			
141	produced,	Per lb. c			
142	cu. ft.	Per lb. e			
143		Per lb. a			
144	Coal per	Per B.H.	.945		1.43
145	H.P. hr.	Equiv. p	1.17		1.66
146		Cost pe	5.35		5.35
147	Cost	Cost pe	.0025		.0038
148	of	Equiv. p	.0031		.0045
149	Coal	Analysi			
150		Mois	1.19		
151		Ash,	74.04		
152	Ash	Vola	2.19		
153		Fixe	22.58		
154		Sul	.33		
155		Heat pe	203000.		313250.
156			100.		100.
157		Heat pe	152000.		204783.
158			75.		65.9
159		Heat los	20200.		24367.
160			9.9		8.
161	Heat	Heat in	84300.		80791.
162			41.5		27.3
163	Balance	Heat in	3620.		4746.
164			1.8		1.4
165		Heat ≡	41250.		42383.
166			20.3		14.3
167		Heat ≡	19000.		15908.
168			9.4		5.4
169		Radiatio	7200.		102817.
171			3.8		30.
171		Heat lo	11190.		35147.
171.1			1.82		4.11
171.2		Heat los	23400.		28733.
			11.5		9.6

				16.	17.	18.	19.	20.	21.	Totals	Average
138	Date, Apr.										
138			Per lb. coal consumed in producer.	74.3	71.5	67.8	78.8	67.4	77.1		72.8
139	St'd gas		Per lb. dry coal.								
140	produced,		Per lb. combustible.								
141	cu. ft.		Per lb. equiv. coal used by plant.								
142			Per lb. equiv. comb. used by plant.								
143	Coal per		Per B.H.P. hr., lbs.	1.94	1.76	1.33	1.4	1.17	.945		1.43
144	H.P. hr.		Equiv. per B.H.P. hr. used by plant, lbs.	1.94	1.94	2.	1.51	1.46	1.17		1.66
145	Cost		Cost per 2000 lbs. at plant, $	5.35	5.35	5.35	5.35	5.35	5.35		5.35
146	of		Cost per B.H.P. hr., $	.0052	.0047	.0036	.0037	.0031	.0025		.0038
147	Coal		Equiv. per B.H.P. hr. used by plant, $	.0052	.0052	.0053	.0040	.0039	.0031		.0045
148			Analysis: (Air dried)								
149			Moisture, %	1.49	1.49	1.49	1.19	1.19	1.19		
150			Ash, %	47.79	47.79	47.79	74.04	74.04	74.04		
151	Ash		Volatile, %	1.05	1.05	1.05	2.19	2.19	2.19		
152			Fixed Carbon, %	49.69	49.69	49.69	22.58	22.58	22.58		
153			Sulphur, %	.3	.3	.3	.33	.33	.33		
154			Heat per hr. in coal, B.t.u.	396000.	390000.	286500.	326500.	277500.	203000.		313250.
155			%	100.	100.	100.	100.	100.	100.		100.
156			Heat per hr. in gas, B.t.u.	256000.	244100.	161700.	231900.	183000.	152000.		204783.
157			%	64.7	62.5	56.5	71.	66.	75.		65.9
158			Heat lost between prod. and eng., B.t.u.	24500.	25400.	16800.	35200.	24100.	20200.		24367.
159			%	6.2	6.5	5.9	10.8	8.7	9.9		8.
160	Heat		Heat in jacket water, B.t.u.	78500.	81700.	77600.	77800.	84850.	84300.		80791.
161			%	19.8	21.	27.1	23.8	30.6	41.5		27.3
162	Balance		Heat in exhaust gases, B.t.u.	5900.	5580.	3720.	5130.	4525.	3620.		4746.
163			%	.7	1.4	1.3	1.6	1.6	1.8		1.4
164			Heat ≡ useful work, B.t.u.	39200.	42500.	41250.	44800.	45300.	41250.		42383.
165			%	9.9	10.9	14.4	13.7	16.3	20.3		14.3
166			Heat ≡ friction, B.t.u.	16750.	17250.	12200.	15500.	14750.	19000.		15908.
167			%	4.2	4.4	4.3	4.7	5.3	9.4		5.4
168			Radiation and unaccounted for, B.t.u.	177000.	162000.	95500.	113500.	61700.	7200.		102817.
169			%	44.5	41.5	33.3	34.8	22.2	3.8		30.
171			Heat lost in refuse, B.t.u.	31000.	63000.	83300.	11200.	11190.	11190.		35147.
171			%	7.83	6.18	3.44	2.92	2.49	1.82		4.11
171.1			Heat lost in Heater, B.t.u.	27250.	31750.	29600.	24950.	35450.	23400.		28733.
171.2			%	6.9	8.1	10.3	7.7	12.8	11.5		9.6

	Date, Apr., 190	Totals	Average
172	Gas leaving producer — A		
173			7.2
174			18.3
175			.1
176			8.2
177			8.
178			58.
179	Temp. water		59.5
180	Temp. water l		151.
181	Temp. Atmos		78.2
182	Manometer Readings. — In		.7
183	At		
184	Er		
185	Pr		
186	Ex		
187	Fuel used in actually producing power. (i.e. fuel less stand-by loss) — Tot	1230.	
188	Dr	1200.	
189	Co	1087.	
190	Co		23.6
191	Dr		23.1
192	Co		20.9
193	Tot	945.6	
194	Co		18.2
195	B.t		313250.
196	Grate Effic		

*

			16.	17.	18.	19.	20.	21.	Totals	Average
172	Gas leaving producer	Analysis by vol. %								
173		CO_2	7.8	5.7	7.6	6.2	6.1	9.8		7.2
174		CO	18.7	20.2	18.1	21.	19.2	12.5		18.3
175		O	.15	.1	.0	.1	.15	.1		.1
176		CH_4	5.8	7.4	6.7	5.8	10.5	12.8		8.2
177		H	3.8	4.7	9.	14.0	8.3	8.0		8.
178		N	62.05	61.9	58.8	52.9	55.7	56.8		58.
179	Temp. water entering exh'st heater, F°		59.	59.5	61.	* 59.5	* 59.5	* 59.5		59.5
180	Temp. water leaving exh'st heater, F°		153.	149.5	152.	* 150.	* 150.	* 150.0		151.
181	Temp. Atmosphere, F°		71.	78.3	80.	80.	80.	80.		78.2
182	Manometer Readings.	In Air tank, Ins. of Water.	.7	.7	.7	.7	.7	.7		.7
183		At engine gas valve, Ins. Water	6.0	1.2	1.2	1.2	1.2	1.2		
184		Engine side of Scrubber, Ins. Water.	1.2	1.2	1.2	1.2	1.2	1.2		
185		Producer side of Scrubber, Ins. Wat.	.9	.9	.9	.9	.9	.9		
186		Exh'st gas exit of heater, Ins. Hg.	3.3	3.3	3.3	3.3	3.3	3.3		
187	Fuel used in actually producing power. (i.e. fuel less stand-by loss)	Total Coal per day as fired, lbs.	256.	264.8	186.	221.	194.5	107.5	1230.	
188		Dry Coal per day, lbs.	250.	258.5	181.9	216.	190.	105.	1200.	
189		Combustible per day, lbs	226.	233.9	164.1	195.1	171.8	95.	1087.	
190		Coal per hr. as fired, lbs.	29.8	29.4	21.6	24.6	20.9	15.3		23.6
191		Dry coal per hr., lbs.	29.1	28.8	21.1	24.	20.4	15.		23.1
192		Combustible per hr. lbs.	26.3	26.0	19.1	21.7	18.5	13.6		20.9
193		Total Carbon gasified per day, lbs.	200.6	189.	126.2	182.	160.	87.8	945.6	
194		Carbon gasified per. hr. lbs.	23.3	21.	14.7	20.2	17.2	12.5		18.2
195		B.t.u. per hr. in coal.	396000.	390000.	286500.	326500.	277500.	203000.		313250.
196	Grate Efficiency									

*Approximate; estimated

UNIVERSITY OF ILLINOIS-URBANA
3 0112 086763775